TÜVRheinland®
DIN CERTCO
Precisely Right.

IGTE

Annex to Solar Keymark Certificate		Licence Number	011-7S2616 F
		Date issued	2021-02-17
		Issued by	DIN CERTCO

Licence holder	CORDIVARI SRL	**Country**	Italy
Brand (optional)		**Web**	www.cordivari.it
Street, Number	Zona Industriale Pagliare	**E-mail**	info@cordivari.it
Postcode, City	64020 Morro D'Oro (TE)	**Tel**	+39 085 804 01

Collector Type	Flat plate collector

Collector name	Gross area (A_G)	Gross length	Gross width	Gross height	Power output per collector Gb = 850 W/m2, Gd = 150 W/m2 & u = 1.3 m/s $\vartheta_m - \vartheta_a$					
					0 K	10 K	30 K	50 K	70 K	108 K
	m²	mm	mm	mm	W	W	W	W	W	W
ASA MQ 2.5 VT 2 CONN	2.50	1250	2000	85	1818	1735	1557	1361	1147	691
Power output per m² gross area					727	694	623	545	459	276

Performance parameters test method	Quasi dynamic									
Performance parameters (related to A_G)	η0, b	a1	a2	a3	a4	a5	a6	a7	a8	Kd
Units	-	W/(m²K)	W/(m²K²)	J/(m³K)	-	J/(m²K)	s/m	W/(m²K⁴)	W/(m²K⁴)	-
Test results	0.729	3.20	0.009	0.000	0.00	13,608	0.000	0.00	0.0	0.982

Incidence angle modifier test method	Quasi dynamic - outdoor								
Incidence angle modifier	Angle	10°	20°	30°	40°	50°	60°	70°	80°	90°
Transversal	$K_{\theta T,coll}$	1.00	0.99	0.98	0.96	0.93	0.87	0.75	0.38	0.00
Longitudinal	$K_{\theta L,coll}$	1.00	0.99	0.98	0.96	0.93	0.87	0.75	0.38	0.00

Heat transfer medium for testing		Water	
Flow rate for testing (per gross area, A_G)	dm/dt	0.020	kg/(sm²)
Maximum temperature difference during thermal performance test	$(\vartheta_m-\vartheta_a)_{max}$	78	K
Standard stagnation temperature (G = 1000 W/m²; ϑ_a = 30 °C)	ϑ_{stg}	207	°C
Maximum operating temperature	$\vartheta_{max\ op}$	199	°C
Maximum operating pressure	$p_{max,op}$	1000	kPa

Testing laboratory	Institut für Gebäudeenergetik, Thermotechnik und Energiespeicherung (IGTE)	http://www.igte.uni-stuttgart.de	
Test report(s)	15COL1316/1 15COLO1316Q/1	**Dated**	09.08.2017 09.08.2017

Comments of testing laboratory — Datasheet version: 6.1, 2019-09-26

Update of the data sheet to current version.
This data sheet replaces the data sheet issued on 27.09.2017

TZS Forschungs- und Testzentrum für Solaranlagen
Institut für Thermodynamik und Wärmetechnik
Universität Stuttgart
Pfaffenwaldring 6, 70550 Stuttgart (Vaihingen)

Annex to Solar Keymark Certificate	Licence Number	011-7S2616 F
Supplementary Information	Issued	2021-02-17

Annual collector output in kWh/collector at mean fluid temperature ϑ_m

Standard Locations		Athens			Davos			Stockholm			Würzburg		
Collector name	ϑ_m	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C
ASA MQ 2.5 VT 2 CONN		2,958	2,178	1,500	2,277	1,631	1,089	1,671	1,135	728	1,824	1,235	779
Annual output per m² gross area		1,183	871	600	911	652	435	668	454	291	730	494	312
Annual efficiency, η_a		67%	49%	34%	56%	40%	27%	57%	39%	25%	59%	40%	25%
Fixed or tracking collector		Fixed (slope = latitude - 15°; rounded to nearest 5°)											
Annual irradiation on collector plane		1765 kWh/m²			1630 kWh/m²			1166 kWh/m²			1244 kWh/m²		
Mean annual ambient air temperature		18.5°C			3.2°C			7.5°C			9.0°C		
Collector orientation or tracking mode		South, 25°			South, 30°			South, 45°			South, 35°		

The collector is operated at constant temperature ϑm (mean of in- and outlet temperatures). The calculation of the annual collector performance is performed with the official Solar Keymark spreadsheet tool Scenocalc Ver. 6.1 (September 2019). A detailed description of the calculations is available at http://www.estif.org/solarkeymarknew/

Additional Information

Collector heat transfer medium					Water-Glycole	
The collector is deemed to be suitable for roof integration					No	
The collector was tested successfully under the following conditions:						
Climate class (A+, A, B or C)					B	--
G (W/m²) >	900	ϑ_a (°C) >	15	H_x (MJ/m²) >		540
Maximum tested positive load					1750	Pa
Maximum tested negative load					1750	Pa
Hail resistance using steel ball (maximum drop height)					2	m

Additional collector attribute(s)

- ☐ Using external power source(s) for normal operation
- ☐ Active or passive measure(s) for self-protection
- ☐ Co-generating thermal and electrical power
- ☐ Façade collector(s)

Energy Labelling Information

	Reference Area, A_{sol} (m²)
ASA MQ 2.5 VT 2 CONN	2.50

Data required for CDR (EU) No 811/2013 - Reference Area A_{sol}

Collector efficiency (η_{col})	58%

Remark: Collector efficiency (ηcol) is defined in CDR (EU) No 811/2013 as collector efficiency of the solar collector at a temperature difference between the solar collector and the surrounding air of 40 K and a global solar irradiance of 1000 W/m², expressed in % and rounded to the nearest integer. Deviating from the regulation ηcol is based on reference area (Asol) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806:2017.

Additional Informative Technical Data

	Hydraulic Designation Code	Aperature Area, A_a (m²)
ASA MQ 2.5 VT 2 CONN	11-V-12S-A.7:2,20850-C.20.6,2455	2.38

Data required for CDR (EU) No 812/2013 - Reference Area A_{sol}

Zero-loss efficiency (η_0)	0.73	--
First-order coefficient (a_1)	3.20	W/(m²K)
Second-order coefficient (a_2)	0.009	W/(m²K²)
Incidence angle modifier IAM (50°)	0.93	--

Remark: The data given in this section are related to collector reference area (A_{sol}) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806. Consistent data sets for either aperture or gross area can be used in calculations like in the regulation 811 and 812 and simulation programs.

DIN CERTCO ● Alboinstraße 56 ● 12103 Berlin, Germany
Tel: +49 30 7562-1131 ● Fax: +49 30 7562-1141 ● E-Mail: info@dincertco.de ● www.dincertco.de